




Through-penetration Firestop Systems

System No. F-A-2326

ANSI/UL1479 (ASTM E814)	CAN / ULC S115
F Rating — 3 Hr	F Rating – 3 Hr
T Rating — 3 Hr	FT Rating – 3 Hr
	FH Rating – 3 Hr
	FTH Rating - 3 Hr



System tested with a pressure differential of 2.5 Pa between the exposed and the unexposed surfaces with the higher pressure on the exposed side.

1. Floor Assembly

Min. 4-1/2 in. (115 mm) thick lightweight or normal weight (100-150 pcf or 1600 - 2400 kg/m³) concrete. Opening shall be circular or rectangular with max diameter or dimensions of 6.4 in. (163 mm).

2. Pipes / Tubes

Single to be installed within the opening. The annular space between the pipes and the periphery of the opening to be 1.22 in (31 mm). Pipes to be rigidly supported on both sides of the floor assembly. The following penetrants may be used:

A. Nom 2-1/2 in (63 mm) diam 0.19 in (4.7 mm) wall thickness PVC pipe for use in closed (process or supply) piping systems.

3. Pipe Covering*

Nom 0.12 in. (19 mm) thick acrylonitrile butadiene/polyvinyl chloride (AB/PVC) flexible foam furnished in the form of tubing. The annular space between the insulated pipe or tubing and periphery of the opening shall be 1.22 in (31 mm). See Plastics+ (QMFZ2) category in the Plastics Recognized Component Directory for names of manufacturers. Any Recognized Component tube insulation material meeting the above specifications and having a UL 94 Flammability Classification of 95-5VA may be used.

4. Firestop System

The Firestop System shall consist of the following:

- A. Packing Material UL Certified gypsum mud, minimum 31 mm width inside the aperture.
- B. Fill, Void or Cavity Material* -1 length of 1 layer of 1/16 in (1.5 mm) by 2 in. (50 mm) wrap flush mounted on the exposed side around the pipe.

Flamro Brandschutz-Systeme GmbH — DG-CR BS

