

System AC Putty

Fire protection system made of sealant for filling and sealing horizontally or vertically aligned structural joints with fire resistance requirements.



Fire Resistance Class

max. EI 240 in acc. with EN 13501-2

Field of Application

- Joints between plasterboard walls, solid walls and solid floors

Products



AC Putty Filler

Cartridge, 310 ml – Art. no. 30005



Mineral wool A1

Reaction to fire class in acc. with EN 13501-1: A1
Melting point ≥ 1000 °C
10 kg bag – Art. no. 01183000



Label

1 piece – Art. no. 14003

System data

Certificate of usability		ETA 21/0108
Thickness of building element	Plasterboard wall	≥ 100
	Solid wall	≥ 150
	Solid floor	≥ 150
Joint width	Plasterboard wall	≤ 30
	Solid wall	≤ 30
	Solid floor	≤ 100
Movement capability	≤ 7.5 % of joint width	

All specifications in mm