

System AWM II KS


Fire protection collar for sealing electrical installation conduits



Products



AWM II
Fire protection collar
 Ø 63 mm – Ø 125 mm
 Art. no. 01142063–01142125



Fasteners
 Ø 63 mm – Ø 125 mm
 Art. no. 01146125



AC Putty Filler
 310 ml cartridge – Art. no. 30005



GFM
Fire protection mortar
 Fibre-free ready-mix dry mortar M20 / MG III in accordance with EN 998-2
 25 kg bag – Art. no. 01167000



General sealing material
 Dimensionally stable, non-combustible (class A1 or A2-s1,d0 in acc. with EN 13501-1) material such as concrete, cement mortar, gypsum mortar



Label
 1 piece – Art. no. 14003

Fire Resistance Class

max. EI 120 in acc. with EN 13501-2

Field of Application

- plasterboard walls, solid walls, solid floors

System Data

Certificate of usability		ETA 11/0372
Thickness of building element	Plasterboard wall	≥ 94
	Solid wall	≥ 100
	Solid floor	≥ 150

All specifications in mm

Services

			max. Ø
	Electrical installation conduits	single	≤ 63 (with/without cables ≤ 21)
		bundled	≤ 125

All specifications in mm